























# DANGEROUS GOODS STORAGE SEGREGATION CHART

CLASS or DIVISION												
		2.1	2.2	3	4.1	4.2	4.3	5.1	5.2	6	8	9
 <b>COMPRESSED GASES</b> 2.1 Flammable gas	2.1	OK to store together	Segregate at least 3m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	Isolate	Segregate at least 3m. Check SDS.	Segregate at least 3m. Check SDS.	OK to store together
 2.2 Non-flammable non-toxic gas	2.2	Segregate at least 3m. Check SDS.	OK to store together	Segregate at least 3m. Check SDS.	May not be compatible. Check SDS	Segregate at least 5m. Check SDS.	May not be compatible. Check SDS	May not be compatible. Check SDS	Segregate at least 5m. Check SDS.	May not be compatible. Check SDS	Segregate at least 3m. Check SDS.	OK to store together
 <b>FLAMMABLE LIQUIDS (and Combustible Liquids)</b>	3	Segregate at least 5m. Check SDS.	Segregate at least 3m. Check SDS.	OK to store together	Segregate at least 3m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	Isolate	Segregate at least 3m. Check SDS.	Segregate at least 3m. Check SDS.	OK to store together
 <b>FLAMMABLE SOLIDS</b> 4.1 Flammable solid	4.1	Segregate at least 5m. Check SDS.	May not be compatible. Check SDS	Segregate at least 3m. Check SDS.	OK to store together	Segregate at least 3m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 3m. Check SDS.	May not be compatible. Check SDS	OK to store together
 4.2 Spontaneously combustible	4.2	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 3m. Check SDS.	OK to store together	Segregate at least 3m. Check SDS.	Segregate at least 5m. Check SDS.	Isolate	Segregate at least 3m. Check SDS.	Segregate at least 3m. Check SDS.	OK to store together
 4.3 Dangerous when wet	4.3	Segregate at least 5m. Check SDS.	May not be compatible. Check SDS	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 3m. Check SDS.	OK to store together	Segregate at least 3m. Check SDS.	Segregate at least 5m. Check SDS.	May not be compatible. Check SDS	May not be compatible. Check SDS	OK to store together
 <b>OXIDISING SUBSTANCES</b> 5.1 Oxidising substance	5.1	Segregate at least 5m. Check SDS.	May not be compatible. Check SDS	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	Segregate at least 3m. Check SDS.	May not be compatible. Check SDS	Segregate at least 5m. Check SDS.	Segregate at least 3m. Check SDS.	Segregate at least 3m. Check SDS.	May not be compatible. Check SDS
 5.2 Oxidising peroxide	5.2	Isolate	Segregate at least 5m. Check SDS.	Isolate	Segregate at least 5m. Check SDS.	Isolate	Segregate at least 5m. Check SDS.	Segregate at least 5m. Check SDS.	OK to store together	Segregate at least 3m. Check SDS.	Segregate at least 3m. Check SDS.	May not be compatible. Check SDS
 <b>TOXIC SUBSTANCES</b>	6	Segregate at least 3m. Check SDS.	May not be compatible. Check SDS	Segregate at least 3m. Check SDS.	Segregate at least 3m. Check SDS.	Segregate at least 3m. Check SDS.	May not be compatible. Check SDS	Segregate at least 3m. Check SDS.	Segregate at least 3m. Check SDS.	OK to store together	May not be compatible. Check SDS	OK to store together
 <b>CORROSIVE SUBSTANCES</b>	8	Segregate at least 3m. Check SDS.	Segregate at least 3m. Check SDS.	Segregate at least 3m. Check SDS.	May not be compatible. Check SDS	Segregate at least 3m. Check SDS.	May not be compatible. Check SDS	Segregate at least 3m. Check SDS.	Segregate at least 3m. Check SDS.	May not be compatible. Check SDS	May not be compatible. Check SDS	OK to store together
 <b>MISCELLANEOUS DGs</b>	9	OK to store together	OK to store together	OK to store together	OK to store together	OK to store together	OK to store together	May not be compatible. Check SDS	May not be compatible. Check SDS	OK to store together	OK to store together	OK to store together